

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0078:204

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: ADEMCO, 165 Eileen Way, Syosset, NY 11791
Contact: Harry Pashkoff (516) 921-6704 Fax (516) 364-6953

DESIGN: Models 6128B, 6137B, 6139B, 6150A-Bay, 6160A-Bay, 6150AAA, 6160AAA Remote Keypads. Models FA215KP, FA260KP, 6148PL2, 6150PL2, 6160PL2, 6148, 6150, 6160, 6150PL3, 6160PL3, 6160SNA, *8150, *8160 Remote Keypads. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessory for use with listee's separately listed compatible fire alarm control units. Base models may have prefixes and/or suffixes to include up to five digit alphanumeric characters. Refer to listee's Installation Instructions Manual for details.

*Rev. 3-07-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 7, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**